

2023 Annual Drinking Water Quality Report

Consumer Confidence Report

City of Pottsboro
Phone Number 903-786-2281

PWS ID Number: **TX 0910004**
PWS Name: **City of Pottsboro**

Annual Water Quality Report for the period of
January 1st, to December 31st, 2023.

This report is intended to provide you with important
information about your drinking water and the efforts
made by the water system to provide safe drinking
water.

City of Pottsboro water system is supplied by
Purchased Surface Water from City of Denison. City
of Denison provides purchase surface water from
Randell Lake & Lake Texoma in Grayson County.

For more information regarding this report contact:

Name: Mitchell Coglon

Phone: 903-327-6744

*Este reporte incluye información importante sobre el agua para tomar.
Para asistencia en español, favor de llamar a; telefono (903)786-
2281*

Public Participation Opportunities

**City Council Meetings are generally held on the
1st Monday of each month at 5:30 p.m. For
additional information contact the City
Secretary's office at 903-786-2281, ext. 4**

Location: Pottsboro City Hall
528 Hwy 120 East
Pottsboro, TX 75076.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water)
include rivers, lakes, streams, ponds, reservoirs, springs, and

wells. As water travels over the surface of the land or through
the ground, it dissolves naturally-occurring minerals and, in
some cases, radioactive material, and can pickup substances
resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be
expected to contain at least small amounts of some
contaminants. The presence of contaminants does not
necessarily indicate that water poses a health risk. More
information about contaminants and potential health effects can
be obtained by calling EPA's Safe Drinking Water Hotline at
(800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which
may come from sewage treatment plants, septic systems,
agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can
be naturally-occurring or result from urban storm water runoff,
industrial or domestic wastewater discharges, oil and gas
production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of
sources such as agriculture, urban storm water runoff, and
residential uses.

- Organic chemical contaminants, including synthetic and
volatile organic chemicals, which are by-products of industrial
processes and petroleum production, and can also come from
gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring
or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes
regulations which limits the amount of certain contaminants in
water provided by public water system. FDA regulations
establish limits for contaminants in bottled water which must
provide the same protection for public health.

Contaminants may be found in drinking water that may cause
taste color, or odor problems. These types of problems are not
necessarily causes for health concerns. for more information on
taste, odor, or color of drinking water, please contact the
system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe drinking water hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Test Results

Definitions: The following contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: Million fibers per liter (a measure of asbestos)
na: not applicable
NTU: nephelometric turbidity units (a measure of turbidity)
pCi/L: picocuries per liter (a measure of radioactivity)
ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt: parts per trillion, or nanograms per liter (ng/L)
ppq: parts per quadrillion, or picograms per liter (pg/L)

Information about Source Water Assessments

A source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:

<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL:

<http://dww.tceq.texas.gov/DWW/>

Source Water Name Location	Type of Water
City of Denison 7311 Hwy 120 E.	Surface Water

2023 Regulated Contaminants Detected

Lead and Copper

Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
 Action Level: The concentration of a contaminant which, if exceeded, triggers or other requirements which water system must follow.

Lead and Copper	Date of Sampled	MCLG	Action Level (AL)	90th Percentile	#Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2023	1.3	1.3	0.157	0	ppm	N	Erosion of natural deposits; leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2023	0	15	3.8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Levels Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2023	21	13.35 – 23.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TThm)*	2023	34	23 – 40.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2021	0.066	0.066 - 0.066	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2023	111	0 – 111	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2021	0.168	0.168 - 0.168	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.129	0.0785 – 0.129	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2021	4.2	4.2 – 4.2	0	50	pCi/L	N	Decay of natural & manmade deposits

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Combined Radium 226-228	2021	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits
Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of measure	Violation (Y/N)	Source of Drinking Water
Chloramine	2023	2.92	1.02 – 3.85	4 Running Annual Average	4	ppm	N	Water additives used to control microbes



City of Denison YEAR 2023 WATER QUALITY DATA

CONTAMINANT	MCL mg/L	DENISON mg/L
pH	8.5	8.0
BARIUM	2.0	0.072
BETA PHOTON EMITTERS	50.0 pCi/L	5.1 pCi/L
CHLORIDE	300	147
SULFATE	300	99.4
FLUORIDE	4.0	0.189
ALKALINITY	N/A	120
TOTAL DISSOLVED SOLIDS	1000	483
TOTAL HARDNESS	N/A	212
SODIUM	N/A	93.5
CALCIUM	N/A	58.8
ZINC	0.2	0.014
CYANIDE	0.2	0.163
IRON	0.3	< 0.05
CHROMIUM	0.1	0.0033
MANGANESE	0.05	0.0088
NEPHELOMETRIC TURBIDITY UNITS (NTU) FINISH WATER		
State regulation: Turbidity must stay below 0.30 NTU 95% of the time.		
DENISON HIGHEST DAILY VALUE		0.24
DENISON AVERAGE DAILY VALUE		0.10

THESE VALUES ARE FROM THE CITY OF DENISON'S FINISH WATER SUPPLY. IF YOUR SYSTEM WAS INDIVIDUALLY TESTED FOR TRIHALOMETHANES, LEAD, OR COPPER YOU MUST RECORD YOUR TEST RESULTS IN YOUR CONSUMER CONFIDENCE REPORT.

SOURCE WATER SUSCEPTIBILITY ASSESSMENT RESULTS

System Susceptibility Summary											
Asbestos	Cyanide	Metals	Microbial	Minerals	Radiochemical	Synthetic Organic Chemicals	Disinfection Byproduct	Volatile Organic Chemicals	Drinking Water Contaminant Candidate	Other	
Low	Low	High	Medium	High	High	High	Medium	High	High	Med.	
Entry Point Susceptibility Summary											
Entry Point ID	Asbestos	Cyanide	Metals	Microbial	Minerals	Radiochemical	Synthetic Organic Chemicals	Disinfection Byproduct	Volatile Organic Chemicals	Drinking Water Contaminant Candidate	Other
001	Low	Low	High	High	High	High	High	Medium	High	High	Med.